



- NOTES:
1. SYMBOLS ARE ELECTRICAL REPRESENTATION ONLY.
 2. TO BE WIRED IN ACCORDANCE WITH NATIONAL ELECTRIC N.E.C. AND LOCAL CODES.
 3. USE COPPER CONDUCTORS ONLY. USE COPPER WIRE ONLY, RATED 70°C OR HIGHER UTILISEZ DES FILS EN CUIVRE SEULEMENT, CLASSE 75°C OU PLUS
 4. CHECK ALL ELECTRICAL CONNECTIONS INSIDE CONTROL BOX FOR TIGHTNESS.

REFERENCE WIRING HARNESS : 2892, 2894, 3032, 3038, 3252, 3253, 3254, & 3255



Ice Bear® 30 Unit
CoolData® Controller Electrical Schematic
for 208/230V 3Ph & 460V 3Ph Applications
Ref. # 3037 Rev E